

Study Area: **SCE Main**  
Thermal Overloads



| Overloaded Facility                                   | Contingency (All and Worst P6)   | Category | Category Description    | Loading % (Baseline Scenarios) |                     |                     |                         |                         | Loading % (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions  |
|---|--|----------|-------------------------|--------------------------------|---------------------|---------------------|-------------------------|-------------------------|-----------------------------------|--|--|---|
|   |  |          |                         | B1_2023 Summer Peak            | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast      | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
| 29253 DVRS_RB_12 500 24374<br>REDBLUFF 500 Ckt 1 or 2 | P1L-SDGE2_22536 N.GILA-22360 IMPRLVLY 500KV &1 -AND- P1L_50511RAS0_Line DEVERS 500.0 to REDBLUFF 500.0 Ckt 2 or 1                        | P6       | Two overlapping singles | <90                            | 91.93               | <90                 | <90                     | <90                     | 92.08                             | 97.19                                    | 113.26                                   | Colorado River Corridor RAS to trip generating facilities connected to Colorado River and Red Bluff Substations |
|   | P1L_50511RAS1_Line DEVERS 500.0 to REDBLUFF 500.0 Ckt 2 or 1 -AND- P1L-SDGE2_22536 N.GILA-22360 IMPRLVLY 500KV &1 with RAS taking action | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | <90                                      | 98.66                                    |   |
| 29400 ANTELOPE 500 29402<br>WIRLWIND 500 1 1          | P1L-50063_Line ANTELOPE 500.0 to WINDHUB 500.0 Ckt 1   | P1       | Single Contingency      | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 101.35                                   | <90                                      | modify the planned Tehachapi cRAS to cover the P1/P2/P4 contingencies   |
|   | P2_33_Whirlwind500kV_SLG at Vincent 500kV w/ loss of Midway-Whirlwind 500kV & Vincent-Whirlwind 500kV w/ series cap bypass of MW_        | P2       | Internal Breaker Fault  | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 119.97                                   | <90                                      |   |
|   | P4_69_Whirlwind_3Ph line fault on Midway-Whirlwind 500 kV with stuck breaker at Whirlwind followed by loss of Vincent-Whirlwind 5        | P4       | stuck breaker           | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 119.7                                    | <90                                      |   |
|   | P1L-50023_Line VINCENT 500.0 to WIRLWIND 500.0 Ckt 3 -AND- P1L-50063_Line ANTELOPE 500.0 to WINDHUB 500.0 Ckt 1                          | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 151.93                                   | 102.97                                   |   |
|   | P1L_50506_Line MIDWAY 500.0 to WIRLWIND 500.0 Ckt 3 -AND- P1L-50063_Line ANTELOPE 500.0 to WINDHUB 500.0 Ckt 1                           | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 120.54                                   | <90                                      |   |



| Overloaded Facility                           | Contingency (All and Worst P6)   | Category | Category Description    | Loading % (Baseline Scenarios) |                     |                     |                         |                         | Loading % (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions  |
|---|--|----------|-------------------------|--------------------------------|---------------------|---------------------|-------------------------|-------------------------|-----------------------------------|--|--|---|
|   |  |          |                         | B1_2023 Summer Peak            | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast      | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
|   | P1DC_PDCI1_PDCI CONVERTER MONOPOLE #1 -AND- P1L-50063_Line ANTELOPE 500.0 to WINDHUB 500.0 Ckt 1                 | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 113.21                                   | <90                                      | rely upon the planned Tehachapi cRAS to drop generation in the Tehachapi area, along with operational mitigation after the first contingency to curtail generation in the Wirlwind and Windhub area as needed |
|   | P1L-22001_Line SYLMAR1 230.0 to SYLMAR S 230.0 Ckt 1 -AND- P1L-50063_Line ANTELOPE 500.0 to WINDHUB 500.0 Ckt 1  | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 113.2                                    | <90                                      |   |
| 29400 ANTELOPE 500 24156 VINCENT 500 1 1      | P1L-50023_Line VINCENT 500.0 to WIRLWIND 500.0 Ckt 3 -AND- P1L-50062_Line ANTELOPE 500.0 to VINCENT 500.0 Ckt 2  | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 140.71                                   | <90                                      |   |
|   | P1L-50023_Line VINCENT 500.0 to WIRLWIND 500.0 Ckt 3 -AND- P1L-50061_Line ANTELOPE 500.0 to VINCENT 500.0 Ckt 1  | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 140.66                                   | <90                                      |   |
| 24594 MW_WRLWND_32 500 29402 WIRLWIND 500 3 1 | P1L-50023_Line VINCENT 500.0 to WIRLWIND 500.0 Ckt 3 -AND- P1L-50064_Line ANTELOPE 500.0 to WIRLWIND 500.0 Ckt 1 | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 112.21                                   | <90                                      | rely upon operational mitigation to curtail generation as system adjustment in the Wirlwind and Windhub areas after the first contingency, and bypass series capacitors as needed                             |
|   | P1L-50063_Line ANTELOPE 500.0 to WINDHUB 500.0 Ckt 1 -AND- P1L-50064_Line ANTELOPE 500.0 to WIRLWIND 500.0 Ckt 1 | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 108.1                                    | <90                                      |   |
| 24594 MW_WRLWND_32 500 29402 WIRLWIND 500 3 1 | P1L_50505_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 2 -AND- P1L_50504_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 1      | P6       | Two overlapping singles | 162.02                         | 92.59               | 92.49               | <90                     | <90                     | 93.43                             | <90                                      | <90                                      | generation redispatch after the initial contingency, bypass series capacitors, and along with existing Path 26 RAS curtailing generation as needed  |



| Overloaded Facility                               | Contingency (All and Worst P6)   | Category | Category Description    | Loading % (Baseline Scenarios) |                     |                     |                         |                         | Loading % (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions   |
|---|--|----------|-------------------------|--------------------------------|---------------------|---------------------|-------------------------|-------------------------|-----------------------------------|--|--|--|
|   |  |          |                         | B1_2023 Summer Peak            | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast      | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |  |
| 24591 MW_VINCNT_11 500 24590 MW_VINCNT_12 500 1 1 | P1L_50505_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 2 -AND- P1L_50506_Line MIDWAY 500.0 to WIRLWIND 500.0 Ckt 3     | P6       | Two overlapping singles | 120.47                         | <90                 | <90                 | <90                     | <90                     | <90                               | <90                                      | <90                                      | generation redispatch after the initial contingency, bypass series capacitors, and along with existing Path 26 and PDCI RASs curtailing generation as needed |
|   | P1DC_PDCI1_PDCI CONVERTER MONOPOLE #1 -AND- P1L_50505_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 2                   | P6       | Two overlapping singles | 108.1                          | <90                 | <90                 | <90                     | <90                     | <90                               | <90                                      | <90                                      |  |
|   | P1DC_PDCI2_PDCI CONVERTER MONOPOLE #2 -AND- P1L_50505_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 2                   | P6       | Two overlapping singles | 108.09                         | <90                 | <90                 | <90                     | <90                     | <90                               | <90                                      | <90                                      |  |
| 24593 MW_VINCNT_21 500 24592 MW_VINCNT_22 500 2 1 | P1L_50504_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 1 -AND- P1L_50506_Line MIDWAY 500.0 to WIRLWIND 500.0 Ckt 3     | P6       | Two overlapping singles | 122.98                         | <90                 | <90                 | <90                     | <90                     | <90                               | <90                                      | <90                                      |  |
|   | P1DC_PDCI1_PDCI CONVERTER MONOPOLE #1 -AND- P1L_50504_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 1                   | P6       | Two overlapping singles | 111.45                         | <90                 | <90                 | <90                     | <90                     | <90                               | <90                                      | <90                                      |  |
|   | P1DC_PDCI2_PDCI CONVERTER MONOPOLE #2 -AND- P1L_50504_Line MIDWAY 500.0 to VINCENT 500.0 Ckt 1                   | P6       | Two overlapping singles | 111.44                         | <90                 | <90                 | <90                     | <90                     | <90                               | <90                                      | <90                                      |  |
| 24594 MW_WRLWND_32 500 29402 WIRLWIND 500 3 1     | P1L-50063_Line ANTELOPE 500.0 to WINDHUB 500.0 Ckt 1 -AND- P1L-50064_Line ANTELOPE 500.0 to WIRLWIND 500.0 Ckt 1 | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 108.1                                    | <90                                      |  |

Study Area: **SCE Main**  
Thermal Overloads



| Overloaded Facility                       | Contingency (All and Worst P6)  | Category | Category Description    | Loading % (Baseline Scenarios) |                     |                     |                         |                         | Loading % (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions   |
|---|---|----------|-------------------------|--------------------------------|---------------------|---------------------|-------------------------|-------------------------|-----------------------------------|--|--|--|
|   |   |          |                         | B1_2023 Summer Peak            | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast      | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |  |
| 24086 LUGO 500 24156 VINCENT 500 1 1      | P1L-50022_Line VINCENT 500.0 to MESA CAL 500.0 Ckt 1 -AND- P1L-50014_Line LUGO 500.0 to VINCENT 500.0 Ckt 2                                     | P6       | Two overlapping singles | <90                            | <90                 | <90                 | <90                     | <90                     | <90                               | 106.43                                   | <90                                      | Operational mitigation to curtail generation in the Tehachapi area after the first contingency, and bypass series capacitors as needed.  |
| 24138 SERRANO 500 24184 serran1i 13.8 1 1 | P1T-52025_Tran SERRANO 500.00 to SERRANO 230.00 Ckt 2 SERRAN2T 13.80 -AND- P1T-52026_Tran SERRANO 500.00 to SERRANO 230.00 Ckt 3 0.00           | P6       | Two overlapping singles | 102.48                         | 104.89              | 104.07              | <90                     | <90                     | 102.27                            | 113.24                                   | 115.24                                   | The long term or 30-minute short term emergency ratings of Serrano 500/230 kV banks should be adequate to dispatch available resources including energy storage and demand response (RDRR) after the first or second contingency |
| 24138 SERRANO 500 24186 serran2i 13.8 2 1 | P1T-52024_Tran SERRANO 500.00 to SERRANO 230.00 Ckt 1 SERRAN1T 13.80 -AND- P1T-52026_Tran SERRANO 500.00 to SERRANO 230.00 Ckt 3 0.00           | P6       | Two overlapping singles | 104.4                          | 106.86              | 106.03              | <90                     | <90                     | 104.19                            | 115.37                                   | 117.4                                    |  |
| 24138 SERRANO 500 24137 SERRANO 230 3 1   | P1T-52025_Tran SERRANO 500.00 to SERRANO 230.00 Ckt 2 SERRAN2T 13.80 -AND- P1T-52024_Tran SERRANO 500.00 to SERRANO 230.00 Ckt 1 SERRAN1T 13.80 | P6       | Two overlapping singles | 101.34                         | 103.73              | 103.46              | <90                     | <90                     | 101.14                            | 111.99                                   | 113.96                                   |  |
| 24076 LAGUBELL 230 24091 MESA CAL 230 1 1 | P1G_24060_Gen ALAMT CTG1/CTG2/STG -AND- P1L-22058_Line LITEHIPE 230.0 to MESA CAL 230.0 Ckt 1   | P3       | G-1 followed by L-1     | 95.97                          | <90                 | 103.11              | <90                     | <90                     | 100.87                            | 101.73                                   | <90                                      | Dispatch available resources including energy storage and demand response for pre-contingency, or reconductor Laguna-Bell Mesa No.1 line   |
|   | P1T-52036_Tran MESA CAL 500.00 to MESACALS 230.00 Ckt 3 MESA3T 13.80 -AND- P1T-52037_Tran MESA CAL 500.00 to MESACALS 230.00 Ckt 4 MESA4T 13.80 | P6       | Two overlapping singles | 103.48                         | 102.46              | 109.82              | <90                     | <90                     | 110.16                            | 109.22                                   | 97.38                                    |  |
|   | P1L-50010_Line LUGO 500.0 to VICTORVL 500.0 Ckt 1 -AND- P1L-22058_Line LITEHIPE 230.0 to MESA CAL 230.0 Ckt 1                                   | P6       | Two overlapping singles | 93.75                          | 90.56               | 103.82              | <90                     | <90                     | 98.9                              | 98.66                                    | <90                                      |  |



| Overloaded Facility                      | Contingency (All and Worst P6)  | Category | Category Description                     | Loading % (Baseline Scenarios) |                     |                     |                         |                         | Loading % (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions  |
|--|---|----------|--|--------------------------------|---------------------|---------------------|-------------------------|-------------------------|-----------------------------------|--|--|---|
|  |   |          |  | B1_2023 Summer Peak            | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast      | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
|  | P1L-22058_Line LITEHIPE 230.0 to MESA CAL 230.0 Ckt 1 -AND- P1L-22059_Line MESA CAL 230.0 to REDONDO 230.0 Ckt 1  | P6       | Two overlapping singles/common structure | 113.39                         | 109.19              | 120.56              | <90                     | <90                     | 118.98                            | 120.25                                   | 106.38                                   |   |
|  | P1L-22093_Line MESACALS 230.0 to LAGUBELL 230.0 Ckt 2 -AND- P1L-22058_Line LITEHIPE 230.0 to MESA CAL 230.0 Ckt 1 | P6/P7    | Two overlapping singles/common structure | 105.72                         | 101.49              | 109.58              | <90                     | <90                     | 109.49                            | 113.64                                   | 105.96                                   |   |
| 24114 PARDEE 230 24128 S.CLARA 230 1 1   | P1L-22913_Line S.CLARA 230.0 to MOORPARK 230.0 Ckt 1 -AND- P1L-22914_Line S.CLARA 230.0 to MOORPARK 230.0 Ckt 2   | P6/P7    | Two overlapping singles/common structure | <90                            | <90                 | 101.71              | <90                     | <90                     | 104.38                            | 109.53                                   | <90                                      | Dispatch available resources including energy storage and demand response (RDRR) in the Ventura/Santa Barbara pre-contingency                     |
| 24114 PARDEE 230 24217 WARNETAP 230 1 1  | P1L-22071_Line PARDEE 230.0 to PASTORIA 230.0 Ckt 1 -AND- P1L-22079_Line PARDEE 230.0 to BAILEY 230.0 Ckt 1       | P6       | Two overlapping singles                  | 106.61                         | 93.89               | <90                 | <90                     | <90                     | <90                               | 111.43                                   | <90                                      | Reduce generation output from Pastoria Energy Facility after the first contingency  |
| 24128 S.CLARA 230 24099 MOORPARK 230 2 1 | P1L-22072_Line PARDEE 230.0 to S.CLARA 230.0 Ckt 1 -AND- P1L-22913_Line S.CLARA 230.0 to MOORPARK 230.0 Ckt 1     | P6       | Two overlapping singles                  | <90                            | <90                 | 96.16               | <90                     | <90                     | 98.84                             | 101.56                                   | <90                                      | Dispatch available resources including energy storage and/or demand response (RDRR) in the Ventura/Santa Barbara area after the first contingency |
| 24044 ELLIS 230 24134 SANTIAGO 230 1 1   | P1L-22035_Line ELLIS 230.0 to JOHANNA 230.0 Ckt 1 -AND- P1L-SDGE2_22536 N.GILA-22360 IMPRLVLY 500KV &1            | P6       | Two overlapping singles                  | 99.41                          | <90                 | 98.52               | <90                     | <90                     | <90                               | 107.21                                   | 104.19                                   | Reduce the San Diego import by dispatching available resources in the San Diego-Imperial Valley area after the first contingency                  |
|  | P1L_SDGE1RAS1A-P1_22930 ECO-22468 MIGUEL 500KV &1 -AND- P1L-22035_Line ELLIS 230.0 to JOHANNA 230.0 Ckt 1         | P6       | Two overlapping singles                  | 101.71                         | <90                 | 92.25               | <90                     | <90                     | <90                               | 109.55                                   | <90                                      |   |



| Overloaded Facility                                   | Contingency (All and Worst P6)   | Category | Category Description    | Loading % (Baseline Scenarios) |                     |                     |                         |                         | Loading % (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions  |
|---|--|----------|-------------------------|--------------------------------|---------------------|---------------------|-------------------------|-------------------------|-----------------------------------|--|--|---|
|   |  |          |                         | B1_2023 Summer Peak            | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast      | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
| 26094 SYLMARLA 230 24147 SYLMAR S 230 bank 'E' or 'F' | P4_53_Sylmar_SLG line fault on Sylmar Bank 'G' 230 kV with stuck breaker at Sylmar followed by loss of Sylmar Bank 'F' or 'E'  | P4       | stuck breaker           | <90                            | <90                 | 103.45              | <90                     | <90                     | 98.41                             | <90                                      | <90                                      | Develop operation procedure or short-term emergency ratings to manage power flow via the banks (Path 41) for pre- or post- contingency; Re-configure the switchyard by adding one-and-half breaker schemes if possible; Remove the three banks between LADWP and SCE along with other facility upgrade; Upgrade the banks E and F |
|   | P1T-22013_Tran SYLMARLA 230.00 to SYLMAR S 230.00 Ckt 'F' or 'E' -AND- P1T-22014_Tran SYLMARLA 230.00 to SYLMAR S 230.00 Ckt G | P6       | Two overlapping singles | <90                            | <90                 | 103.46              | <90                     | <90                     | 98.42                             | <90                                      | <90                                      |   |

| Substation    | Contingency (All and Worst P6)   | Category | Category Description    | Voltage PU (Baseline Scenarios) |                     |                     |                         |                         | Voltage PU (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions  |
|---------------|--|----------|-------------------------|---------------------------------|---------------------|---------------------|-------------------------|-------------------------|------------------------------------|--|--|---|
|               |  |          |                         | B1_2023 Summer Peak             | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast       | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
| MOHAVE 500 kV | P1L_50508_Line LUGO 500.0 to MOHAVE 500.0 Ckt 1 -AND- P1L-50018_Line MOHAVE 500.0 to ELDORDO 500.0 Ckt 1 | P6       | Two overlapping singles | 0.44                            | 0.46                | no issue            | 0.56                    | 0.55                    | 0.47                               | 0.41                                     | 0.55                                     | Exiting NVE RAS to protect its 69 kV system   |
| GOLETA 230 kV | P1L-22909_Line S.CLARA 230.0 to GOLETA 230.0 Ckt 1 -AND- P1SVD_24321_SVD S.CLARA 230                     | P6       | Two overlapping singles | no issue                        | no issue            | no issue            | no issue                | no issue                | no issue                           | 0.86                                     | no issue                                 | Dispatch available resources including energy storage and demand response (RDRR) in the Goleta/S.Clara area after the first contingency |
| GOLETA 230 kV | P1SVD_24321_SVD S.CLARA 230 -AND- P1L-22909_Line S.CLARA 230.0 to GOLETA 230.0 Ckt 1                     | P6       | Two overlapping singles | no issue                        | no issue            | no issue            | no issue                | no issue                | no issue                           | 0.86                                     | no issue                                 |   |

Study Area: SCE Main

Voltage Deviation



| Substation | Contingency (All and Worst P6) | Category | Category Description | Post Cont. Voltage Deviation % (Baseline Scenarios) |                     |                     |                         |                         | Post Cont. Voltage Deviation % (Sensitivity Scenarios) |  |  | Project & Potential Mitigation Solutions |
|------------|--------------------------------|----------|----------------------|---|---------------------|---------------------|-------------------------|-------------------------|--|--|--|--|
|            |                                |          |                      | B1_2023 Summer Peak                                 | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast                           | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |  |
|            |                                |          |                      |   |                     |                     |                         |                         |  |  |  |  |

No voltage deviation issues were identified



Study Area: SCE Main

Transient Stability



| Contingency   | Category | Category Description   | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions |
|---|----------|------------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|--------------------------------|
|   |          |                        | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |                                |
|   |          |                        | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |                                |
| 01_Lugo500kV_P1.3: 3PH 4 cycle fault at Lugo 500kV w/ loss of Lugo-Victorville 500kV  | p1       | Single Contingency     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 02_IV500kV_P1.3: 3PH 4 cycle fault at Imperial Valley 500kV w/ loss of Imperial Valley-North Gila 500kV   | p1       | Single Contingency     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 03_PV500kV_P1.1: 3PH 4 cycle fault at Palo Verde w/ loss of Palo Verde Unit No.1  | p1       | Single Contingency     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 09_Vincent500kV_P1.2: 3PH 4 cycle fault at Vincent 500kV w/ loss of Vincent-Whirlwind 500kV & series cap bypass of MW_Vincent_12-Vincent 500kV                            | p1       | Single Contingency     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 14_Miraloma500kV_P1.2: 3PH 4 cycle fault at Miraloma 500kV w/ loss of Miraloma-Serrano No.2 500kV & EastTS-MiraLoma 500kV line shunt                                      | p1       | Single Contingency     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 24_N.Gila500kV_P1.2: 3PH 4 cycle fault at N.Gila 500kV w/ loss of Hoodoo Wash-N.Gila 500kV w/ loss of Santiago Synchronous Condensers                                     | p1       | Single Contingency     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 30_N.Gila500kV_P1.2: 3PH 4 cycle fault at N.Gila 500kV w/ loss of Hoodoo Wash-N.Gila 500kV including loss of Devers SVCs & Cap Bank                                       | p1       | Single Contingency     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 31_Vincent500kV_P2.3: 1PH 4 cycle fault at Vincent 500kV w/ loss of Mesa-Vincent 500kV & Midway-Vincent No.2 500kV w/ series cap bypass of MW_Vincent_12-Vincent500kV     | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 33_Whirlwind500kV_P2.3: 1PH 4 cycle fault at Vincent 500kV w/ loss of Midway-Whirlwind 500kV & Vincent-Whirlwind 500kV w/ series cap bypass of MW_Vincent_12-Vincent500kV | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 34_Lugo500kV_P2.3: 1PH 4 cycle fault at Lugo 500kV w/ loss of Lugo-Rancho Vista 500kV & Lugo-Vincent No.1 500kV w/ series cap bypass of Eld_Lugo_14-Lugo500kV             | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |

Study Area: SCE Main

Transient Stability



| Contingency  | Category | Category Description   | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions |
|--|----------|------------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|--------------------------------|
|  |          |                        | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |                                |
|  |          |                        | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |                                |
| 36_Lugo500kV_P2.3: 1PH 4 cycle fault at Lugo 500kV w/ loss of Lugo-Mira Loma No.2 500kV & Eldorado-Lugo 500kV w/ series cap bypass of Lugo-Lgo_Mohve_11_500kV                  | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 38_Lugo500kV_P2.3: 1PH 4 cycle fault at Lugo 500kV w/ loss of Lugo-Rancho Vista 500kV & Lugo-Vincent No.1 500kV w/ loss of Eld_Lugo_14-Lugo500kV line shunt                    | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 40_Lugo500kV_P2.3: 1PH 4 cycle fault at Lugo 500kV w/ loss of Lugo-Miraloma No.2 500kV & Eldorado-Lugo 500kV w/ loss of Lugo-Lgo_Mohve_11 500kV line shunt                     | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 42_Miraloma500kV_P2.3: 1PH 4 cycle fault at Mira Loma 500kV w/ loss of Mira Loma-Rancho Vista 500kV & Mira Loma-Serrano No.1 500kV w/ loss of EastTS-MiraLoma 500kV line shunt | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 44_Devers500kV_P2.3: 1PH 4 cycle fault at Devers 500kV w/ loss of Devers-Red Bluff No.1 500kV & Devers-Valley No.1 500kV including loss of Devers SVCs & Cap Bank              | p2       | Internal Breaker Fault | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 46_Sylmar230kV_3Ph line fault on Pardee-Sylmar No.1 230 kV with stuck breaker at Sylmar followed by loss of Gould-Sylmar 230 kV  | p4       | stuck breaker          | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 48_Sylmar230kV_3Ph line fault on Gould-Sylmar 230 kV with stuck breaker at Sylmar followed by loss of Sylmar Bank 'E'  | p4       | stuck breaker          | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 50_Sylmar230kV_3Ph line fault on Pardee-Sylmar No.1 230 kV with stuck breaker at Sylmar followed by loss of Sylmar Bank 'F'  | p4       | stuck breaker          | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 52_Sylmar230kV_1-Ph fault on Sylmar Bank 'G' 230 kV with stuck breaker at Sylmar followed by loss of Sylmar Bank 'E'   | p4       | stuck breaker          | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 54_Devers500kV_3Ph line fault on Devers-Red Bluff No.1 500 kV with stuck breaker at Devers followed by loss of Devers-Valley No.1 500 kV                                       | p4       | stuck breaker          | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |

Study Area: SCE Main

Transient Stability



| Contingency   | Category | Category Description | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions  |
|---|----------|----------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|---|
|   |          |                      | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |   |
|   |          |                      | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
| 55_Lugo500kV_3Ph line fault on Lugo-Rancho Vista 500 kV with stuck breaker at Lugo followed by loss of Lugo-Vincent No.1 500 kV                                   | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 56_Lugo500kV_3Ph line fault on Lugo-Vincent No.2 500 kV with stuck breaker at Lugo followed by loss of Lugo-Victorville 500 kV                                    | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 57_MiraLoma500kV_3Ph line fault on Mira Loma-Rancho Vista 500 kV with stuck breaker at Mira Loma followed by loss of Mira Loma-Serrano No.1 500 kV                | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 59_MiraLoma230kV_3Ph line fault on Mira Loma-Olinda 230 kV with stuck breaker at Mira Loma followed by loss of Chino-Mira Loma No.3 230 kV                        | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 61_RanchoVista230kV_3Ph line fault on Etiwanda-Rancho Vista No.1 230 kV with stuck breaker at Rancho Vista followed by loss of Mira Loma-Rancho Vista No.2 230 kV | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met. However, dynamic models (repc_a and repc_b) of some IBR resources need to be tuned |
| 63_Serrano230kV_3Ph line fault on Chino-Serrano 230 kV with stuck breaker at Serrano followed by loss of Lewis-Serrano No.1 230 kV                                | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 65_Vincent500kV_3Ph line fault on Mesa-Vincent 500 kV with stuck breaker at Vincent followed by loss of Midway-Vincent No.2 500 kV                                | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met. However, dynamic models (repc_a and repc_b) of some IBR resources need to be tuned |
| 67_Vincent230kV_3Ph line fault on Mesa-Vincent No.2 230 kV with stuck breaker at Vincent followed by loss of Santa Clara-Vincent 230 kV                           | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 69_Whirlwind230kV_3Ph line fault on Midway-Whirlwind 500 kV with stuck breaker at Whirlwind followed by loss of Vincent-Whirlwind 500 kV                          | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 70_Chino230kV_3Ph line fault on Chino-Viejo 230 kV with stuck breaker at Chino followed by loss of Chino-Serrano 230 kV   | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |

Study Area: SCE Main

Transient Stability



| Contingency  | Category | Category Description | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions  |
|--|----------|----------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|---|
|  |          |                      | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |   |
|  |          |                      | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
| 71_Ellis230kV_3Ph line fault on Barre-Ellis No.2 230 kV with stuck breaker at Ellis followed by loss of Ellis-Santiago 230 kV                              | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met. However, dynamic models (repc_a and repc_b) of some IBR resources need to be tuned |
| 75_Olinda230kV_3Ph line fault on Olinda-Walnut 230 kV with stuck breaker at Olinda followed by loss of Mira Loma-Olinda 230 kV                             | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met. However, dynamic models (repc_a and repc_b) of some IBR resources need to be tuned |
| 76_RioHondo230kV_3Ph line fault on Mesa-Rio Hondo No.2 230 kV with stuck breaker at Rio Hondo followed by loss of Rio Hondo-Vincent No.2 230 kV            | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met. However, dynamic models (repc_a and repc_b) of some IBR resources need to be tuned |
| 77_SantaClara230kV_3Ph line fault on Moorpark-Santa Clara No.1 230 kV with stuck breaker at Santa Clara followed by loss of Goleta-Santa Clara No.1 230 kV | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met. However, dynamic models (repc_a and repc_b) of some IBR resources need to be tuned |
| 79_Santiago230kV_3Ph line fault on SONGS-Santiago No.2 230 kV with stuck breaker at Santiago followed by loss of Ellis-Santiago 230 kV                     | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 80_Pardee230kV_3Ph line fault on Bailey-Pardee 230 kV with stuck breaker at Pardee followed by loss of Pardee-Vincent No.1 230 kV                          | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 82_Pardee230kV_3Ph line fault on Pardee-Santa Clara 230 kV with stuck breaker at Pardee followed by loss of Pardee-Pastoria-Warne 230 kV                   | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 84_Pardee230kV_3Ph line fault on Pardee-Sylmar No.1 230 kV with stuck breaker at Pardee followed by loss of Moor Park-Pardee No.3 230 kV                   | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 85_VillaPark230kV_3Ph line fault on Barre-Villa Park 230 kV with stuck breaker at Villa Park followed by loss of Serrano-Villa Park No.1 230 kV            | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 86_Lewis230kV_3Ph line fault on Barre-Lewis 230 kV with stuck breaker at Lewis followed by loss of Lewis-Serrano No.2 230 kV                               | p4       | stuck breaker        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |

Study Area: SCE Main

Transient Stability



| Contingency   | Category | Category Description    | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions  |
|---|----------|-------------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|---|
|   |          |                         | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |   |
|   |          |                         | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |   |
| 101_Lighthipe_NR230kV_P5 1-PH Fault on Lighthipe Bus, N-RBD Relay, delayed clearing 29 cycles                               | P5.5     | non-redundant relay     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 99_P5_LagunaBell_NR230kV_P5 1-PH Fault on Laguna Bell Bus, N-RBD Relay, delayed clearing 29 cycles                          | P5.5     | non-redundant relay     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 106_Antelope500kV_P6.1: 3PH 4 cycle fault at Antelope 500kV w/ loss of Antelope-Whirlwind and Antelope-Vincent No.1         | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 107_Antelope500kV_P6.1: 3PH 4 cycle fault at Antelope 500kV w/ loss of Antelope-Whirlwind and Antelope-Windhub              | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 109_Eldorado500kV_P6.1: 3PH 4 cycle fault at Eldorado 500kV w/ loss of Eldorado-Lugo and Eldorado-Mohave                    | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 110_Lugo500kV_P6.1: 3PH 4 cycle fault at Lugo 500kV w/ Eldorado-Lugo and Lugo-Mohave  | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 111_Devers500kV_P6.1: 3PH 4 cycle fault at Devers 500kV w/ loss of Devers-RedBluff No.1 & No.2 500 kV                       | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 112_Devers500kV_P6.1: 3PH 4 cycle fault at Devers 500kV w/ loss of Devers-Valley No.1 & No.2 500 kV                         | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 113_ECO500kV_P6.1: 3PH 4 cycle fault at ECO 500 w/ loss of ECO-Miguel & Ocotillo-Suncrest 500 kV                            | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 114_MiraLoma500kV_P6.1: 3PH 4 cycle fault at Mira Loma 500kV w/ loss of Mesa-Mira Loma 500kV & Mira Loma 4AA Bank           | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |
| 116_Mohave500kV_P6.1: 3PH 4 cycle fault at Mohave 500kV w/ loss of Eldorado-Mohave and Lugo-Mohave                          | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met. However, dynamic models (repc_a and repc_b) of some IBR resources need to be tuned |
| 117_RanchoVista500kV_P6.1: 3PH 4 cycle fault at Rancho Vista 500kV w/ loss of Lugo-Rancho Vista & Rancho Vista-Serrano No.1 | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met   |

Study Area: SCE Main

Transient Stability



| Contingency  | Category | Category Description    | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions |
|--|----------|-------------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|--------------------------------|
|  |          |                         | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |                                |
|  |          |                         | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |                                |
| 119_Serrano500kV_P6.1: 3PH 4 cycle fault at Serrano 500kV w/ loss of Alberhill-Serrano & Rancho Vista-Serrano No.1       | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 120_Serrano500kV_P6.1: 3PH 4 cycle fault at Serrano 500kV w/ loss of Alberhill-Serrano & Mira Loma-Serrano No.2          | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 122_Midway500kV_P6.1: 3PH 4 cycle fault at Midway 500 kV w/ loss of Midway-Vincent No.1 & Midway-Whirlwind No.3 + No RAS | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 123_SONGS230kV_P6.1: 3PH 4 cycle fault at SONGS 230 kV w/ loss of SONGS-San Luis Rey No.1 & No.2 230kV                   | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 124_Vincent500kV_P6.1: 3PH 4 cycle fault at Vincent 500kV w/ loss of Lugo-Vincent No.1 & No.2                            | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 125_Whirlwind500kV_P6.1: 3PH 4 cycle fault at Whirlwind 500kV w/ loss of Midway-Whirlwind No.3 & Windhub-Whirlwind       | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 126_Whirlwind500kV_P6.1: 3PH 4 cycle fault at Whirlwind 500kV w/ loss of Whirlwind-Windhub & Antelope-Whirlwind          | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 127_Mesa500kV_P6.1: 3PH 4 cycle fault at Mesa 500kV w/ loss of Mesa-Vincent 500kV & Mesa-Miraloma                        | p6       | Two overlapping singles | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 128_IPPDC_bipole_P7.2: SLG fault at Adelanto 500kV followed by loss of IPP Bipole Converters with North-to-South flow    | p7       | common structure        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 129_PDCI_bipole_SPS_P7.2: SLG fault at Sylmar SCE followed by loss of PDCI Bipole with North-to-South flow               | p7       | common structure        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 130_Center230kV_P7.1: 1PH 4 cycle fault at Center 230kV w/ loss of Alamitos-Center and Center-Del Amo                    | p7       | common structure        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 131_Center230kV_P7.1: 1PH 4 cycle fault at Center 230kV w/ loss of Center-Mesa and Center-Olinda                         | p7       | common structure        | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |



Study Area: SCE Main

Transient Stability



| Contingency   | Category | Category Description | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions |
|---|----------|----------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|--------------------------------|
|   |          |                      | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |                                |
|   |          |                      | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |                                |
| 132_Johanna230kV_P7.1: 1PH 4 cycle fault at Johanna 230kV w/ loss of Ellis-Santiago & Ellis-Johanna                       | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 133_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Center-Mesa & Mesa-Walnut                                  | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 135_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Mesa-Walnut & Center-Olinda                                | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 136_Redondo230kV_P7.1: 1PH 4 cycle fault at Redondo 230kV w/ loss of La Fresa-Redondo No.1 & No.2                         | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 137_Redondo230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Mesa-Redondo & Lighthipe-Redondo                        | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 138_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Mesa-Redondo & La Fresa-Laguna Bell                        | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 140_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Litehipe-Mesa & Del Amo-Laguna Bell                        | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 142_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Litehipe-Mesa & Laguna Bell-Mesa No.2                      | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 143_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Mesa-Rio Hondo No.1 & No.2                                 | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 144_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Mesa-Vincent No.2 230kV & Goodrich-Gould                   | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 145_Mesa230kV_P7.1: 1PH 4 cycle fault at Mesa 230kV w/ loss of Mesa-Vincent No.1 & Goodrich-Mesa                          | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 146_MiraLoma500kV_P7.1: 1PH 4 cycle fault at Mira Loma 500kV w/ loss of Mesa-Mira Loma 500kV & Chino-Mira Loma No.3 230kV | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |

Study Area: SCE Main

Transient Stability



| Contingency   | Category | Category Description | Transient Stability Performance |                     |                         |                              |  | Potential Mitigation Solutions |
|---|----------|----------------------|---------------------------------|---------------------|-------------------------|------------------------------|--|--------------------------------|
|   |          |                      | Baseline Scenarios              |                     |                         | Sensitivity Scenarios        |  |                                |
|   |          |                      | B2_2026 Summer Peak             | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | S1_2026 SP High CEC Forecast | S3_2023 OP Heavy Renewable & Min Gas Gen |                                |
| 147_MiraLoma230kV_P7.1: 1PH 4 cycle fault at Mira Loma 230kV w/ loss of Mira Loma-Walnut 230kV & Mira Loma-Olinda                   | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 148_RanchoVista230kV_P7.1: 1PH 4 cycle fault at Rancho Vista 230kV w/ loss of Mira Loma-Rancho Vista No.1 & No.2 230kV              | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 149_Santiago230kV_P7.1: 1PH 4 cycle fault at Santiago 230kV w/ loss of Ellis-Santiago & Johanna-Santiago                            | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 150_Serrano500kV_P7.1: 1PH 4 cycle fault at Serrano 500kV w/ loss of Mira Loma-Serrano No.2 500kV & Rancho Vista-Serrano No.1 500kV | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 151_Serrano230kV_P7.1: 1PH 4 cycle fault at Serrano 230kV w/ loss of Serrano-Villa Park No.1 & No.2 230kV                           | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 152_Viejo230kV_P7.1: 1PH 4 cycle fault at Viejo 230kV w/ loss of San Onofre-Serrano 230kV & Chino-Viejo 230kV                       | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |
| 153_Vincent230kV_P7.1: 1PH 4 cycle fault at Vincent 230kV w/ Rio Hondo-Vincent No.1 & No.2 230kV                                    | p7       | common structure     | stable                          | stable              | stable                  | stable                       | stable                                   | WECC Criteria met              |



Study Area: SCE Main



Single Contingency Load Drop

| Worst Contingency | Category | Category Description | Amount of Load Drop (MW) |                     |                     |                         |                         |                              |  |  | Potential Mitigation Solutions |
|-------------------|----------|----------------------|--------------------------|---------------------|---------------------|-------------------------|-------------------------|------------------------------|--|--|--------------------------------|
|                   |          |                      | B1_2023 Summer Peak      | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |                                |
|                   |          |                      |                          |                     |                     |                         |                         |                              |  |  |                                |

No single contingency resulted in total load drop of more than 250 MW

Study Area: **SCE Main**



Single Source Substation with more than 100 MW Load

| Substation | Load Served (MW)    |                     |                     |                         |                         |                              |  |  | Potential Mitigation Solutions |
|------------|---------------------|---------------------|---------------------|-------------------------|-------------------------|------------------------------|--|--|--------------------------------|
|            | B1_2023 Summer Peak | B2_2026 Summer Peak | B3_2031 Summer Peak | B4_2023 Spring Off-Peak | B5_2026 Spring Off-Peak | S1_2026 SP High CEC Forecast | S2_2023 SP Heavy Renewable & Min Gas Gen | S3_2023 OP Heavy Renewable & Min Gas Gen |                                |
|            |                     |                     |                     |                         |                         |                              |  |  |                                |

No single source substation with more than 100 MW