

APPENDIX A: System Data

Intentionally left blank

1. Existing Generation

Table A1-1: Existing generation plants in the CAISO planning area

PTO	Existing Generation Nameplate Capacity (MW)										
	Nuclear	Natural Gas	Hydro	Solar	Wind	Biogas	Biomass	Geo-thermal	Battery Storage	Other	Total
PG&E	2352	15818	8290	4429	1476	103	451	1074	980	1737	36710
SCE	0	11334	2620	8050	3890	142	4	336	1765	2996	31137
SDG&E	0	3616	40	2324	701	17	0	0	520	249	7467
VEA	0	0	0	115	0	0	0	0	0	0	115
Total	2352	30768	10950	14918	6067	262	455	1410	3265	4982	75429

For detail resource information, please refer to Master Control Area Generating Capability List in OASIS under ATLAS REFERENCE tab at the following link: <http://oasis.caiso.com/mrioasis>

2. Retired Generation (non-OTC)

Table A2-1: Generation plants projected to be retired in planning horizon

PTO Area	Project	Capacity (MW)	Expected Retirement Year
None	None	None	None

3. OTC Generation

Table A3-1: Once-through cooled generation in the California ISO Balancing Authority Area

Generating Facility	Owner	Existing Unit/ Technology ¹ (ST=Steam CCGT=Combine- Cycled Gas Turbine)	State Water Resources Control Board (SWRCB) Compliance Date	Retirement Date (If already retired or have plans to retire)	Net Qualifying Capacity (NQC) (MW)	Repowering Capacity ² (MW) and Technology ³ (approved by the CPUC and CEC)	In-Service Date for CPUC and CEC-Approved Repowering Resources	Notes
Humboldt Bay	PG&E	1 (ST)	12/31/2010	9/30/2010	52	163 MW (10 ICs)	9/28/2010	Retired 135 MW and repowered with 10 ICs (163 MW)
		2 (ST)	12/31/2010		53			
Contra Costa	GenOn	6 (ST)	12/31/2017	April 30, 2013	337	Replaced by 760 MW Marsh Landing power plant (4 GTs)	May 1, 2013	New Marsh Landing GTs are located next to retired generating facility.
		7 (ST)	12/31/2017		337			
Pittsburg	GenOn	5 (ST)	12/31/2017	12/31/2016	312	Retired (no repowering plan)	N/A	
		6 (ST)	12/31/2017		317			
Potrero	GenOn	3 (ST)	10/1/2011	2/28/2011	206	Retired (no repowering plan)	N/A	
Moss Landing	Dynergy	1 (CCGT)	12/31/2020* (see notes at far right column)	N/A	510	The State Water Resources Control Board (SWRCB) approved mitigation plan (Track 2 implementation plan) for Moss Landing Units 1 & 2.	N/A	The State Water Resources Control Board (SWRCB) approved OTC Track 2 mitigation plan for Moss Landing Units 1 & 2.
		2 (CCGT)	12/31/2020* (see notes at far right column)	N/A	510			
		6 (ST)	12/31/2020 (see notes)	1/1/2017	754	Retired (no repowering plan)	N/A	
		7 (ST)	12/31/2020 (see notes)	1/1/2017	756	Retired (no repowering plan)	N/A	

¹ Most of the existing OTC units, with the exception of Moss Landing Units 1 and 2, are steam generating units.

² The ISO, through Long-Term Procurement Process and annual Transmission Planning Process, worked with the state energy agencies and transmission owners to implement an integrated and comprehensive mitigation plan for the southern California OTC and SONGS generation retirement located in the LA Basin and San Diego areas. The comprehensive mitigation plan includes preferred resources, transmission upgrades and conventional generation.

³ IC (Internal Combustion), GT (gas turbine), CCGT (combined cycle gas turbine)

Generating Facility	Owner	Existing Unit/ Technology ¹ (ST=Steam CCGT=Combine- Cycled Gas Turbine)	State Water Resources Control Board (SWRCB) Compliance Date	Retirement Date (If already retired or have plans to retire)	Net Qualifying Capacity (NQC) (MW)	Repowering Capacity ² (MW) and Technology ³ (approved by the CPUC and CEC)	In-Service Date for CPUC and CEC-Approved Repowering Resources	Notes
Morro Bay	Dynegy	3 (ST)	12/31/2015	2/5/2014	325	Retired (no repowering plan)	N/A	
		4 (ST)	12/31/2015	2/5/2014	325	Retired (no repowering plan)	N/A	
Diablo Canyon Nuclear Power Plant	PG&E	1 (ST)	12/31/2024	11/2/2024	1122	PG&E plans to replace with renewable energy, energy efficiency and energy storage.	N/A	On June 21, 2016, PG&E has announced that it planned to retire Units 1 and 2 by 2024 and 2025, respectively. On November 30, 2020, the State Water Resources officially amended compliance schedule. ⁴
		2 (ST)	12/31/2024	8/26/2025	1118			
Mandalay	GenOn	1 (ST)	12/31/2020	2/6/2018	215	Retired (no repowering) SCE plans to replace with renewable energy and storage		Mandalay generating facility was retired on February 6, 2018.
		2 (ST)	12/31/2020	2/6/2018	215			
Ormond Beach	GenOn	1 (ST)	12/31/2020	12/31/2023	741	To be retired (no repowering)	N/A	On November 30, 2020, the SWRCB officially amended the compliance schedule.
		2 (ST)	12/31/2020	12/31/2023	775			
El Segundo	NRG	3 (ST)	12/31/2015	7/27/2013	335	560 MW El Segundo Power Redevelopment (CCGTs)	August 1, 2013	Unit 3 was retired on 7/27/2013.
		4 (ST)	12/31/2015	12/31/2015	335	Retired (no repowering)	N/A	Unit 4 was retired on December 31, 2015.
Alamitos	AES	1 (ST)	12/31/2020	1/1/2020	175	640 MW CCGT on the same property	4/1/2020	Units 1, 2 and 6 were retired on January 1, 2020 to provide emission offsets to repowering project (non-OTC units). On November 30, 2020, the SWRCB officially amended the
		2 (ST)	12/31/2020	1/1/2020	175			
		3 (ST)	12/31/2020	12/31/2023	332			
		4 (ST)	12/31/2020	12/31/2023	336			
		5 (ST)	12/31/2020	12/31/2023	498			
		6 (ST)	12/31/2020	1/1/2020	495			

⁴ https://www.waterboards.ca.gov/water_issues/programs/ocean/cwa316/docs/otc_policy_2020/otc2020.pdf

Generating Facility	Owner	Existing Unit/ Technology ¹ (ST=Steam CCGT=Combine- Cycled Gas Turbine)	State Water Resources Control Board (SWRCB) Compliance Date	Retirement Date (If already retired or have plans to retire)	Net Qualifying Capacity (NQC) (MW)	Repowering Capacity ² (MW) and Technology ³ (approved by the CPUC and CEC)	In-Service Date for CPUC and CEC-Approved Repowering Resources	Notes
								compliance schedule for Units 3, 4 and 5.
Huntington Beach	AES	1 (ST)	12/31/2020	1/1/2020	226	644 MW CCGT on the same property	3/1/2020	Unit 1 was retired to provide emission offsets to repowering project (non-OTC units). On November 30, 2020, the SWRCB officially amended the compliance schedule for Unit 2.
		2 (ST)	12/31/2020	12/31/2023	226			
		3 (ST)	12/31/2020	11/1/2012	227			Units 3 and 4 were retired in 2012 and converted to synchronous condensers in June 2013 to operate on an interim basis. On December 31, 2017, these two synchronous condensers were retired.
		4 (ST)	12/31/2020	11/1/2012	227			
Redondo Beach	AES	5 (ST)	12/31/2020	12/31/2021	179	To be retired	N/A	Unit 7 was retired to provide emission offsets to repowering project at Huntington Beach. On November 30, 2020, the SWRCB officially amended the compliance schedule for Units 5, 6 and 8.
		6 (ST)	12/31/2020	12/31/2021	175			
		7 (ST)	12/31/2020	10/1/2019	493			
		8 (ST)	12/31/2020	12/31/2021	496			
San Onofre Nuclear Generating Station	SCE/ SDG&E	2 (ST)	12/31/2022	June 7, 2013	1122	Retired (no repowering)	N/A	
		3 (ST)	12/31/2022		1124			
Encina	NRG	1 (ST)	12/31/2017	3/1/2017	106	500 MW (5 GTs or peakers) Carlsbad		OTC Unit 1 was retired on 12/31/2017. Units 2-
		2 (ST)	12/31/2017	12/31/2018 ⁵	103			

⁵ The State Water Resources Control Board approved extending the compliance date for Encina Units 2 to 5 for one year to December 31, 2018 due to delay of Carlsbad Energy Center in-service date.

Generating Facility	Owner	Existing Unit/ Technology ¹ (ST=Steam CCGT=Combine- Cycled Gas Turbine)	State Water Resources Control Board (SWRCB) Compliance Date	Retirement Date (If already retired or have plans to retire)	Net Qualifying Capacity (NQC) (MW)	Repowering Capacity ² (MW) and Technology ³ (approved by the CPUC and CEC)	In-Service Date for CPUC and CEC-Approved Repowering Resources	Notes
		3 (ST)	12/31/2017	12/31/2018	109	Energy Center, located on the same property as the Encina Power Plant.	New resources (Carlsbad Energy Center) achieved commercial operation on 12/11/2018	5 were retired on 12/31/2018.
		4 (ST)	12/31/2017	12/31/2018	299			
		5 (ST)	12/31/2017	12/31/2018	329			
South Bay (707 MW)	Dynegy	1-4 (ST)	12/31/2011	12/31/2010	692	Retired (no repowering)	N/A	Retired 707 MW (CT non-OTC) – (2010-2011)

4. Planned Generation

Table A4-1: Planned Generation

PTO Area	Project	Capacity (MW)	Expected In-service Year
None	None	None	None

5. Reactive Resources

Table A5-1: Summary of key existing reactive modeled in ISO reliability assessments

Substation	Capacity (Mvar)	Technology
Gates	225	Shunt Capacitors
Los Banos	225	Shunt Capacitors
Gregg	150	Shunt Capacitors
McCall	132	Shunt Capacitors
Mesa (PG&E)	100	Shunt Capacitors
Metcalf	350	Shunt Capacitors
Olinda	200	Shunt Capacitors
Table Mountain	454	Shunt Capacitors
Devers	156 & 605 (dynamic capability)	Static VAR Compensator
Rector	200	Static VAR Compensator
Santiago	3x81	Synchronous Condensers
Sunrise San Luis Rey	63	Shunt Capacitors
Southbay / Bay Boulevard	100	Shunt Capacitors
Mira Loma 230kV	158	Shunt Capacitors
Mira Loma 500kV	300	Shunt Capacitors
Suncrest	126	Shunt Capacitors
Penasquitos	126	Shunt Capacitors
San Luis Rey	2x225	Synchronous Condensers
Talega	2x225	Synchronous Condensers
Talega	100	STATCOM
Miguel	2x225	Synchronous Condensers
San Onofre	225	Synchronous Condensers

6. Special Protection Schemes

Table A6-1: Existing Special Protection Schemes in the PG&E area

PTO	Area	SPS Name
PG&E	Central Coast / Los Padres	Mesa and Santa Maria Undervoltage SPS
	Central Coast / Los Padres	Divide Undervoltage SPS
	Central Coast / Los Padres	Temblor-San Luis Obispo 115 kV Overload Scheme
	Bulk	COI RAS
	Bulk	Colusa SPS
	Bulk	Diablo Canyon SPS
	Bulk	Gates 500/230 kV Bank #11 SPS
	Bulk	Midway 500/230 kV Transformer Overload SPS
	Bulk	Path 15 IRAS
	Bulk	Path 26 RAS North to South
	Bulk	Path 26 RAS South to North
	Bulk	Table Mt 500/230 kV Bank #1 SPS
	Central Valley	Drum (Sierra Pacific) Overload Scheme (Path 24)
	Central Valley	Stanislaus – Manteca 115 kV Line Load Limit Scheme
	Central Valley	Vaca-Suisun 115 kV Lines Thermal Overload Scheme
	Central Valley	West Sacramento 115 kV Overload Scheme
	Central Valley	West Sacramento Double Line Outage Load Shedding SPS Scheme
	Greater Fresno Area	Ashlan SPS
	Greater Fresno Area	Atwater SPS
	Greater Fresno Area	Gates Bank 11 SPS
	Greater Fresno Area	Helms HTT RAS
	Greater Fresno Area	Helms RAS
	Greater Fresno Area	Henrietta RAS
	Greater Fresno Area	Herndon-Bullard SPS
	Greater Fresno Area	Kerckhoff 2 RAS
	Greater Fresno Area	Reedley SPS
	Greater Bay Area	Metcalf SPS
	Greater Bay Area	SF RAS
	Greater Bay Area	South of San Mateo SPS
	Greater Bay Area	Metcalf-Monta Vista 230kV OL SPS
Greater Bay Area	San Mateo-Bay Meadows 115kV line OL	

PTO	Area	SPS Name
	Greater Bay Area	Moraga-Oakland J 115kV line OL RAS
	Greater Bay Area	Grant 115kV OL SPS
	Greater Bay Area	Oakland 115 kV C-X Cable OL RAS
	Greater Bay Area	Oakland 115kV D-L Cable OL RAS
	Greater Bay Area	Sobrante-Standard Oil #1 & #2-115kV line
	Greater Bay Area	Gilroy SPS
	Greater Bay Area	Transbay Cable Run Back Scheme
	Humboldt	Humboldt – Trinity 115kV Thermal Overload Scheme
	North Valley	Caribou Generation 230 kV SPS Scheme #1
	North Valley	Caribou Generation 230 kV SPS Scheme #2
	North Valley	Cascade Thermal Overload Scheme
	North Valley	Hatchet Ridge Thermal Overload Scheme
	North Valley	Coleman Thermal Overload Scheme

Table A6-2: Existing Special Protection Schemes in SCE area

PTO	Area	SPS Name
SCE	Northern Area	Antelope-RAS
	Northern Area	Big Creek / San Joaquin Valley RAS
	Northern Area	Whirlwind AA-Bank RAS
	Northern Area	Pastoria Energy Facility RAS (PEF RAS)
	Northern Area	Midway-Vincent RAS (SCE MVRAS)
	North of Lugo	Bishop RAS
	North of Lugo	High Desert Power Project RAS (HDPP RAS)
	North of Lugo	Kramer RAS (Retired)
	North of Lugo	Mojave Desert RAS
	North of Lugo	Victor Direct Load Tripping Scheme
	East of Lugo	Ivanpah RAS
	East of Lugo	Lugo - Victorville RAS
	Eastern Area	Devers RAS
	Eastern Area	Colorado River Corridor RAS
	Eastern Area	Inland Empire Area RAS (Retirement pending)
	Eastern Area	Blythe Energy RAS
	Eastern Area	MWD Eagle Mountain Thermal Overload Scheme
	Eastern Area	Mountain view Power Project Remedial Action Scheme
	Metro Area	El Nido LCR RAS (Replaced with El Nido/El Segundo N-2 CRAS Analytic)
	Metro Area	El Segundo RAS (Replaced with El Nido/El Segundo N-2 CRAS Analytic)
Metro Area	South of Lugo (SOL) N-2 RAS	
Metro Area	Mira Loma Low Voltage Load Shedding (LVLS)	

Table A6-3: Existing Special Protection Schemes in the SDG&E

PTO	Area	SPS Name
SDG&E	SDG&E	TL695A at Talega SPS
	SDG&E	TL682/TL685 SPS
	SDG&E	TL633 At Rancho Carmel SPS
	SDG&E	TL687 at Borrego SPS
	SDG&E	TL13816 SPS
	SDG&E	TL13835 SPS
	SDG&E	Border TL649 Overload SPS
	SDG&E	Crestwood TL626 at DE SPS for Kumeyaay Wind Generation
	SDG&E	Crestwood TL629 at CN SPS for Kumeyaay Wind Generation
	SDG&E	Crestwood TL629 at DE SPS for Kumeyaay Wind Generation
	SDG&E	230kV TL 23040 Otay Mesa – Tijuana SPS (currently disabled and will not be enabled until its need is reevaluated with CENACE)
	SDG&E	230kV Otay Mesa Energy Center Generation SPS
	SDG&E	ML (Miguel) Bank 80/81 Overload SPS
	SDG&E	CFE SPS to protect lines from La Rosita to Tijuana
	SDG&E	TL 50001 IV Generator Drop SPS
	SDG&E	TL 50003 IV Generator Drop SPS
	SDG&E	TL 50004 IV Generator Drop SPS
	SDG&E	TL 50005 IV Generator Drop SPS
	SDG&E	TL 50001 IV Generator SPS
	SDG&E	Imperial Valley BK80 RAS
	SDG&E	TL23040 IV 500 kV N-1 RAS
SDG&E	TL 23054 / TL23055 RAS	
SDG&E	Path 44 South of SONGS Safety Net	