



California ISO

ISO Planning Standards Remedial Action Scheme Guidelines Update

Draft Final
Proposal

December 8, 2022

Infrastructure & Operational Planning

Table of Contents

Contents

1	Introduction	3
2	Stakeholder Process	4
3	Draft Final Proposal	5
3.1	Removal of Redundant Language in the RAS guidelines.....	5
3.2	Refinements to Existing RAS Guidelines	7
4	Next Steps	12
5	Schedule	12

1 Introduction

The ISO resumed the Planning Standards – Remedial Action Scheme Guideline Update stakeholder process¹ in July 2022 to discuss potential revisions to the ISO Remedial Action Scheme (RAS) guidelines which are part of the California ISO Planning Standards (ISO Standards). The RAS guidelines, along with the other requirements in the Planning Standards, complement the existing NERC/WECC Reliability Standards and ensure a secure and reliable ISO infrastructure development. After the stakeholder meeting on July 22, 2022, the ISO received comments from various stakeholders². The stakeholders' comments provided the basis for the straw proposal that was presented at the stakeholder meeting on September 26, 2022.³

After the stakeholder meeting on September 26, 2022, the ISO received comments from the California Wind Energy Association (CalWEA), Rev Renewables (REV), Pacific Gas & Electric Company (PG&E), Southern California Edison (SCE) and San Diego Gas & Electric Company (SDG&E). The following is the summary of the submitted comments, based on the major categories that are provided in the following discussions. The comments, as well as ISO's responses to those comments, are posted on the stakeholder initiative page⁴.

1.1. General support of the RAS guideline review initiative

In general, the stakeholders that submitted comments expressed general support for the ISO's efforts in simplifying the RAS design in the straw proposal. However, each of the entities that submitted comments have their own specific comments for further consideration. The ISO, in conjunction with revising the straw proposal, is providing responses to specific stakeholders' comments in a stakeholder comments matrix that is posted prior to the next stakeholder meeting. Please see footnote below for the link to more detailed responses to each of the comments submitted.

The following provides a summary of major comments that were received as well as the ISO's responses to those major concerns.

1.2. Removal of redundant language in the RAS guidelines

¹ <https://stakeholdercenter.caiso.com/StakeholderInitiatives/Planning-standards-remedial-action-scheme-guidelines-update>

² <https://stakeholdercenter.caiso.com/Comments/AllComments/c36dd6bb-4e13-48d2-99ba-ab7f14137591>

³ <http://www.caiso.com/InitiativeDocuments/StrawProposal-PlanningStandards-RemedialActionSchemeGuidelinesUpdate.pdf>

⁴ <https://stakeholdercenter.caiso.com/StakeholderInitiatives/Planning-standards-remedial-action-scheme-guidelines-update>

1.3. CalWEA, SDG&E and SCE support the proposed removal of redundant RAS language as discussed in Section 3.1 of the Straw Proposal as those are already included in the NERC PRC-012-2 standard. PG&E and REV have no comments at this time. Therefore, the ISO is proceeding with the removal of redundant ISO SPS guidelines as discussed in the previous Straw Proposal.

1.4. Implementation of proposed standards and guidelines

CalWEA and REV wanted to know implementation details (i.e., when the RAS standard and guideline updates become effective). They also expressed concerns that the proposed standards and guidelines could have potential impact on the generation projects currently in the queue regarding network upgrade requirements.

The ISO noted that the updated RAS standards and guidelines will become effective after the Board's consideration and approval. The ISO will work with generation developers and transmission owners to implement the new standards and guidelines. It is noted that as part of the proposal, ISO-GRAS7 guideline may allow relaxing RAS requirements as a temporary "bridge" to system reinforcements.

1.5. Standards versus guidelines

SDG&E and SCE commented that some of the proposed RAS guidelines (i.e., G-RAS3, G-RAS4 and G-RAS6)⁵, should be made as standards instead of guidelines for implementation. The ISO opined that the design, implementation, and operation of RAS is a complex process requiring the consideration of many factors, and that designating those guidelines as standards is not appropriate at this time.

1.6. Other comments regarding detailed RAS standards and guidelines

The ISO responded to other detailed comments regarding specific proposed RAS standards and guidelines in the responses to the stakeholders in the posted stakeholder comment matrix. In addition, the ISO also considered some of those suggestions and incorporated them into the updated standards and guidelines as discussed further in the following Section 3.2.

2 Stakeholder Process


The ISO is at the "Draft Final Proposal" stage in Planning Standards - RAS

⁶ The generating facilities selected to participate in a generation dropping RAS should be optimized, so that generation deliverability and feasible congestion mitigation benefits are maximized.

guidelines update (RAS) stakeholder process. Figure 1 below shows the status of the overall RAS stakeholder process.

The purpose of the Draft Final Proposal is to incorporate stakeholder feedback in revising the straw proposal. This process is part of the typical stakeholder initiative process. The process concludes with the ISO publishing a draft final proposal, soliciting stakeholder feedback prior to taking the resultant changes to the ISO Board of Governors for approval.

Figure 1 – A Typical Stakeholder Initiative Process



3 Draft Final Proposal

After review of the submitted comments that were received, the ISO revises the RAS straw proposal in the following proposed RAS standards and guidelines. The revision is highlighted in the following revised standards and guidelines.

3.1 Removal of Redundant Language in the RAS guidelines

During this stakeholder process, the ISO received feedback that stakeholders supported removing redundant language that the NERC PRC-012-2 also covers. In addition, the ISO also replaced references to Special Protection System (SPS) with Remedial Action Scheme (RAS), which is now officially used in NERC standards. Since there was no objection to the removal of these guidelines, there is no further change to the following section.

The following are further discussions of SPS guidelines that are eliminated due to redundancy with the requirements from PRC-012-2 standards.

- 1) **ISO SPS 1** – “the overall reliability of the system should not be degraded after the combined addition of the SPS”. This is eliminated as the PRC-012-2 Requirements R1, R2 and R3. The PRC-012-2 R1 requires the RAS-entity to provide documentation to support the proposed RAS. Requirement R2 requires CAISO/I&OP

that the Reliability Coordinator (RC) to review and provide feedback to the RAS-entity. Requirement R3 requires that the RAS-entity resolves issues that were identified by the RC to obtain approval from the RC prior to implementation of the RAS.

- 2) **ISO SPS 2** – “the SPS needs to be highly reliable. Normally, SPS failure will need to be determined to be non-credible. In situations where the design of the SPS requires WECC approval, the WECC Remedial Action Scheme Design Guide will be followed.” This language is removed as the PRC-012-2 Requirements R1, R2, R3, R5, R6, R7 and R8. The PRC-012-2 Requirements R1, R2 and R3 indicated that the proposed RAS needs to obtain approval from the RC. The PRC-012-2 R5, R6 and R7 requires that the RAS-entity participates in the assessment to determine the causes of the RAS failure if it occurred, and to follow up with and implement the Corrective Action Plan (CAP). The PRC-012-2 R8 requires the RAS entity to perform functional test periodically to ensure proper operation of the RAS.
- 3) **ISO SPS4** – this guideline is removed as the language is redundant with the PRC-012-2 R1, R2 and R3 requirements for new RAS, or R4 requirement for the existing RAS.
- 4) **ISO SPS5** – this guideline is removed as it is covered by the PRC-012-2 R1 – R3 for new RAS and R4 for existing RAS.
- 5) **ISO SPS8** – this guideline is removed as the language is redundant with PRC-012-2 R1 – R3 for new RAS and R4 for existing RAS.
- 6) **ISO SPS9** – this guideline is removed as it is redundant with PRC-012-2 R1 – R3 requirements; the new RAS is to be reviewed and approved by the RC (i.e., RC West).
- 7) **ISO SPS11** – this guideline is removed as it is superseded with PRC-012-2 R1 – R3 requirements when reviewing proposed new RAS.
- 8) **ISO SPS12** – this guideline is removed as it is superseded with PRC-012-2 R8 requirement where each RAS-entity shall participate in performing a functional test of each of its RAS to verify the overall RAS performance.
- 9) **ISO SPS13** – this guideline is removed as it is superseded by PRC-012-2 R1 and R9 requirements where the RAS-entity provides required document to the RC and the RC is to maintain and update a RAS database.
- 10) **ISO SPS14** – this guideline is removed as it is superseded by PRC-012-2 R4 where the ISO Planning Coordinator (PC) performs periodic review and evaluation of the existing RAS, as well as by TPL-001-5 and its subsequent version

requirements where the ISO PC performs reliability assessment of its controlled transmission system in the annual transmission planning process.

- 11) **ISO SPS15** – this guideline is removed as it is redundant with PRC-012-2 R1 – R3 and R8 requirements where the RAS entity is responsible in providing its design and document of the proposed RAS, as well as periodic testing of the existing RAS.
- 12) **ISO SPS17** – this guideline is removed as it is redundant with PRC-012-2 R1 – R3 requirements in which the RAS entity provides required design and implementation of the proposed RAS to the RC for review and approval.

3.2 Refinements to Existing RAS Guidelines

The following includes proposed additions, changes and modifications of the proposed RAS standards and guidelines based on the comments received from the stakeholders. As mentioned in the previous Straw Proposal, the new RAS standard is identified as S-RAS, whereas RAS guideline is identified as G-RAS. **The proposed modifications as well as rationale for those changes are highlighted yellow.**

- 1) **ISO S-RAS1** – New RAS implementation should meet the NERC PRC-012-2 (or subsequent version) requirements.

There is no change to the above language from the previous version of the Straw Proposal. With the above new standard, it supersedes the guidelines for new RAS proposals that were removed as discussed in Section 3.1 due to redundancy to PRC-012-2 and requires new RAS implementation to meet PRC-012-2 (or subsequent version) requirements.

- 2) **ISO S-RAS2** – The RAS should not be proposed for mitigating reliability concerns under normal conditions (i.e., Category P0).

There is no change to the above language from the previous version of the Straw Proposal. RAS is typically designed to mitigate reliability concerns under contingency conditions. While it is rare to have RAS to mitigate reliability concerns under normal condition, the ISO would like to reinforce the design principles to have RAS designed for mitigating reliability concerns for contingency conditions only. Having RAS to mitigate reliability concerns under normal condition would increase the frequency of utilizing the RAS, increases the operational complexity as the system can become more difficult to operate due to proliferation of the RAS that may cause coordination concern among the RAS in close proximity with other RAS in the vicinity area. In addition, it may also increase the likelihood of curtailment of resources that are needed for resource adequacy.

3) **ISO G-RAS3** – The following are guidelines for optimizing resources to participate in the RAS design and implementation so that generation deliverability benefit is maximized:

A. The RAS should be designed for simple operation to trip a fixed set of generation under specific contingencies⁶.

i. It should not be implemented with complex design whose operation is predicated on different flow levels on monitored transmission facilities to dynamically trip variable amounts of generation.

ii. A RAS should not include logics to dynamically arm and trip various generation levels to achieve transmission facility flow objectives. Modeling of RAS dynamic arming and tripping of generation is not feasible in the ISO market.

The ISO is merging the above ISO G-RAS3.A guideline with G-RAS4.G based on the comments from CalWEA that these guidelines are overlapping. The ISO agrees that these guidelines should be included together but is keeping the entire language of ISO G-RAS4.G for clarity.

B. The RAS should trip load and/or resources that have the effectiveness factors greater than 10% on the constraints that need mitigation such that the magnitude of load and/or resources to be tripped is minimized.

i. As a matter of principle, voluntary load tripping and other pre-determined mitigations should be implemented before involuntary load tripping is utilized. Involuntary load tripping should not be included in the RAS in the high density load area(s).

ii. In addition, the RAS should avoid tripping the station service and generator auxiliary load as tripping these loads could affect generator tripping mechanism.

This guideline is proposed as a result of stakeholder feedback for simple RAS. It is also based on feedback from the ISO Power System and Market Technology Division that complex RAS⁷ is challenging to be implemented in the ISO market. The ISO also added ISO G-RAS3.B.ii based on comments received from PG&E.

4) **ISO G-RAS4** –

⁶ The generating facilities selected to participate in a generation dropping RAS should be optimized, so that generation deliverability and feasible congestion mitigation benefits are maximized.

⁷ Complex RAS is referred to RAS that is designed to arm and trip different levels of generation or load based on various conditions of flows on monitored transmission facilities.

The RAS must be simple and manageable:

- A. There should be no more than 6 contingencies (P1 – P7) that would trigger the operation of a RAS.
- B. The RAS should not be monitoring more than 4 system elements or variables. A variable can be a combination of related elements, such as a path flow, if it is used as a single variable in the logic equation.
- C. Overlapping RAS (i.e., two different RAS monitoring one or more of the same elements or contingencies) is not allowed.
- D. A RAS that includes storage facilities and is implemented to operate when there is an excess of generation should not also be implemented to operate when there is an excess of charging. Similarly, a RAS that includes storage facilities and is implemented to operate when there is an excess of charging should not also be implemented to operate when there is an excess of generation. This set up will help make the RAS simpler for design, implementation, and modeling.

The following are examples that illustrate the above guideline:

1. **Example 1** – total resource with excess of generation output level that triggers reliability concerns

For this example, let's assume that we have a combined hybrid resource that consists of 200 MW solar generation and 105 MW of battery energy storage system (BESS). The reliability issue is identified with total aggregated generation output of or exceeding 100 MW under contingency condition. With BESS at 105 MW discharging, the total generation output for the hybrid facility is 305 MW. With BESS at 90 MW charging, the total generation output for the hybrid facility is 110 MW. The RAS will then need to trip both the solar generation and the BESS regardless of the BESS' operating mode.

On the other hand, if the total hybrid facility aggregated output is -105 MW (i.e., BESS in maximum charging mode and solar generation is unavailable due to nighttime hours), the same RAS should not be designed to operate. This would simplify the RAS design, implementation and modeling in the ISO market.

- Example 2** – total resource with excess of charging output level that triggers reliability concerns

For this example, let's assume that we have a 100 MW of solar generation and 205 MW of BESS. The reliability issue is identified with total aggregated charging load of 100 MW or more under contingency condition. The RAS would then be operated if solar generation is at 100 MW and BESS charging at 205 MW (for a total aggregated charging load of 105 MW), or if solar generation is at 0 MW (i.e., unavailable in nighttime hours), and the BESS is charging at 205 MW (which could occur in early hours of the day) resulting in a total charging load of 205 MW.

On the other hand, if the total hybrid facility aggregated output is 0 – 100 MW due to solar generation output and BESS is at 0 MW output, the same RAS should not be designed to operate. Similarly to the above example, this setup would simplify the RAS design, implementation and modeling.

- E. The RAS should only monitor overloading facilities no more than 1 substation beyond the first point of interconnection **for generating facility, or bulk transmission substation where loading concerns are identified**. The impact of generation or load dropping on a remote facility tends to be ineffective due to the electrical distance within the network between the generation or load to be dropped and the remote facility. Remote monitoring of facilities may also add substantial complexity to system operation and should be avoided.

The ISO provided the additional language above based on the comments received from PG&E suggesting the language be added to address the conditions where RAS would be necessary other than for generation interconnection. In addition, “for generating facility” was added to provide further clarification to what facility was intended in response to SCE’s comments.

- F. A RAS should not require real-time operator actions to arm or disarm the RAS or change its set points.

5) ISO S-RAS5

If the RAS is designed for new generation interconnection, the RAS should not include the involuntary interruption of firm customer load. Voluntary interruption of load paid for by the generator is acceptable.

The above is from the ISO SPS7 guideline, and is proposed to become a standard to ensure that firm customer load is not impacted with the addition of new generation, unless the load interruption is voluntary and paid for by the generator.

6) ISO –G-RAS6

“The total net amount of generation tripped by a RAS for a single contingency (P1

or P2) should not exceed the ISO's largest single generation contingency (currently one Diablo Canyon unit at 1150 MW). The total net amount of generation tripped by a RAS for multiple contingencies (P3 – P7) cannot exceed 1400 MW. These amounts should be based on the maximum **interconnection service capacity** of the generating facilities that are to be tripped rather than their current MW production. This amount is related to the minimum amount of contingency reserves that the ISO has historically been required to carry. The quantities of generation specified in this standard represent the current upper limits for generation tripping. These quantities will be reviewed periodically and revised as needed. In addition, the actual amount of generation that can be tripped is project specific and may depend on specific system performance issues to be addressed. Therefore, the amount of generation that can be tripped for a specific project may be lower than the amounts provided in this guideline.”

The above guideline (originally ISO SPS3) is proposed to remain as a guideline due to retirement outlook for Diablo Canyon Power Plant (DCPP) remains undetermined. Originally, DCPP Units 1 and 2 were scheduled to retire on expiration of their respective operating licenses on November 2024 and August 2025. However, the State of California is considering potential extension of the operation of DCPP to meet higher energy demand.

The ISO added P2 based on the comments received from PG&E that the proposed Straw Proposal did not mention the generation tripping limit for P2 contingency. In addition, “interconnection service” capacity was added above in response to SCE’s comments for further clarification.

The current ISO guideline for the maximum amount of generation that can be curtailed for a single contingency via the use of RAS cannot exceed the maximum capacity of one Diablo Canyon unit at 1150 MW. The guideline for multiple contingency is 1400 MW and these limits were based on the minimum amount of contingency reserves that ISO has historically been required to carry. The other critical contingency that affects the ISO's contingency reserve requirements is the loss of the Pacific DC Intertie (PDCI), which is the transmission system that provides linkage between the Pacific Northwest and Southern California bulk electric system. The scheduling allocations on the PDCI to the ISO BAA is about 52.3% of the total flow, with the rest going to LADWP BAA. If the PDCI flow is at its maximum path rating limit of 3220 MW, the scheduling allocations to the ISO could be 1684 MW or higher to about 2000 MW if additional energy flows through LADWP system to the ISO. A review of the historical contingency reserves in the ISO BAA from January 1, 2018 to September 15, 2022 indicated that for 99% of the time, the amount of contingency reserves awarded in the ISO BAA are 1400 MW or higher. The mean value is estimated to be about 2261 MW. Thus 1400

MW is considered practically the minimum amount of contingency reserve in the ISO BAA.

7) ISO G-RAS7

“The ISO, in coordination with affected parties, may relax RAS requirements, including exceptions to complex RAS, as a temporary “bridge” to long-term system reinforcements that are being considered for ISO management and Board approval. Normally this “bridging” period would be limited to the time it takes to implement a specified transmission solution. An example of a relaxation of RAS guidelines and standard requirements would be to allow 8 initiating events rather than limiting the RAS to 6 initiating events until the identified system reinforcements are placed into service.” In addition, for multiple contingencies that are not in the ISO market model these guidelines and standards may be more flexible.

The above guideline (formerly ISO SPS10) is proposed to remain as a guideline. There are several reasons to keep this guideline to: provide flexibility to enable temporary “bridge” to system reinforcements. With the projected higher demand as well as increase in resource interconnections to the ISO-controlled grid, there needs to be flexibility in implementing temporary “bridge” to long-term system reinforcements. The ISO added the above language based on PG&E’s comments that relaxing RAS requirements be considered only when there is commitment for a long-term transmission plan that addresses the reliability concerns that trigger the need for relaxing the RAS in the first place. The ISO also added a note allowing some flexibility in the guidelines for multiple contingencies that are not modeled in the ISO market since the market modeling issues described during this initiative would not be an issue. Additional language to include “guidelines and standard requirements” is added to provide further clarification to SCE’s comments.

4 Next Steps

The ISO requests additional feedback from stakeholders on the RAS guideline updates in this straw proposal. The ISO will host a stakeholder call on December 15, 2022 to review the revised straw proposal, and encourages all stakeholders to submit comments. Comments will be due on December 29, 2022.

5 Schedule

The following schedule is updated to include the ISO proposed timeline for bringing the Final Proposal to the Board for consideration and approval.

Table 1 Schedule

Item	Date
Post Straw Proposal	September 19, 2022
Stakeholder Call	September 26, 2022
Stakeholder Comments Due	October 10, 2022
Post Draft Final Proposal	December 8, 2022
Stakeholder Call	December 15, 2022
Stakeholder Comments Due	December 29, 2022
ISO Board Meeting	January 31-February 1, 2023