

24402 ANTELOPE	66.0	24401 ANTELOPE	230 1 1	line_P6_205897_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 4	P6	N-1-1	<100	<100	107.9	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				line_P6_205923_Line NEENACH 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2	P6	N-1-1	<100	<100	104.9	<100	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency
				tran_P6_207154_Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2 0.00 Tran ANTELOPE 66.00 to ANTELOPE	P6	N-1-1	131.3	159.1	199.8	102.2	118.2	<100	164.7	<100	131.3	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
24402 ANTELOPE	66.0	24401 ANTELOPE	230 2 1	line_P6_205701_Line ANTELOPE 66.0 to NEENACH 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 4	P6	N-1-1	<100	<100	108.2	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				line_P6_205894_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 1	P6	N-1-1	<100	<100	110.3	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				line_P6_205987_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 4	P6	N-1-1	<100	<100	111.8	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				line_P6_205925_Line NEENACH 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 4	P6	N-1-1	<100	<100	108.3	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				tran_P6_207128_Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 1 0.00 Tran ANTELOPE 66.00 to ANTELOPE	P6	N-1-1	131.7	159.4	200.3	102.5	118.6	<100	165.0	<100	131.7	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
24402 ANTELOPE	66.0	24401 ANTELOPE	230 4 1	line_P6_205699_Line ANTELOPE 66.0 to NEENACH 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2	P6	N-1-1	<100	<100	107.8	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				line_P6_205894_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 1	P6	N-1-1	<100	<100	109.5	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				line_P6_205895_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2	P6	N-1-1	<100	<100	111.4	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				line_P6_205923_Line NEENACH 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2	P6	N-1-1	<100	<100	107.9	<100	<100	<100	<100	<100	<100	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
				tran_P6_207126_Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 1 0.00 Tran ANTELOPE 66.00 to ANTELOPE	P6	N-1-1	131.6	159.4	200.2	102.4	118.5	<100	165.0	<100	131.6	Congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency	
24402 ANTELOPE	66.0	24420 NEENACH	66.0 1 1	line_P6_202257_Line PARDEE 230.0 to BAILEY 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	113.0	133.8	<100	132.9	<100	114.5	<100	135.9	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency	
				tran_P6_207228_Tran BAILEY 66.00 to BAILEY 230.00 Circuit 2 0.00 Tran BAILEY 66.00 to BAILEY	P6	N-1-1	<100	114.3	132.5	<100	134.1	<100	114.9	<100	133.1	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency	
24403 BAILEY	230	24115 PASTORIA	230 1 1	line_P6_201989_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS	
				line_P6_202125_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	108.2	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS	
				line_P6_202126_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	109.8	<100	<100	<100	<100	<100	System re-dispatch after initial contingency	
				line_P6_202136_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line Pardee- Pastoria- Warner 230 kV line	P6	N-1-1	<100	<100	<100	107.4	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
				line_P6_202323_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	107.7	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
24404 BAILEY	66.0	24452 TAP 85	66.0 1 1	line_P6_202257_Line PARDEE 230.0 to BAILEY 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	123.1	119.8	120.2	119.4	<100	120.8	125.7	<100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency		
				tran_P6_207228_Tran BAILEY 66.00 to BAILEY 230.00 Circuit 2 0.00 Tran BAILEY 66.00 to BAILEY	P6	N-1-1	120.6	118.8	125.2	119.5	<100	<100	121.0	123.3	<100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency	
24420 NEENACH	66.0	24452 TAP 85	66.0 1 1	line_P6_202257_Line PARDEE 230.0 to BAILEY 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	143.4	138.8	138.8	139.6	115.3	<100	140.3	131.6	118.0	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency	
				tran_P6_207228_Tran BAILEY 66.00 to BAILEY 230.00 Circuit 2 0.00 Tran BAILEY 66.00 to BAILEY	P6	N-1-1	143.5	139.2	142.1	139.7	116.3	<100	142.0	131.8	115.4	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency	

Study Area: **SCE Tehachapi & Big Creek Corridor**



Single Contingency Load Drop

Worst Contingency	Category	Category Description	Amount of Load Drop (MW)								Potential Mitigation Solutions	
			2026 Summer Peak	2029 Summer Peak	2034 Summer Peak	2029 Summer-Off Peak	2026 Spring-Off Peak	2029 Spring-Off Peak	2029 SP High CEC Forecast	2026 SP Heavy Renewable & Min Gas Gen		2026 Spring Shoulder-Peak

No single contingency resulted in total load drop of more than 250 MW

2024-2025 ISO Reliability Assessment - Preliminary Study Results

Study Area: **SCE Tehachapi & Big Creek Corridor**



Single Source Substation with more than 100 MW Load

Substation	Load Served (MW)									Potential Mitigation Solutions
	2026 Summer Peak	2029 Summer Peak	2034 Summer Peak	2029 Summer-Off Peak	2026 Spring-Off Peak	2029 Spring-Off Peak	2029 SP High CEC Forecast	2026 SP Heavy Renewable & Min Gas Gen	2026 Spring Shoulder-Peak	

No single source substation with more than 100 MW