

Overloaded Facility	Contingency (All and Worst PE)	Category	Category Description	Loading % (Baseline Scenario)						Loading % (Sensitivity Scenario)				Project & Potential Mitigation Solutions
				2026 Summer Peak	2029 Summer Peak	2034 Summer Peak	2029 Summer-Of-Peak	2026 Spring-Of-Peak	2029 Spring-Of-Peak	2029 SP High CEC Forecast	2026 SP Heavy Renewable & Min Gas Gen	2026 Spring Shoulder Peak		
24087 MAGUNDEN 230 24401 ANTELOPE 230 1 1	line_P6_201254_Line BIG CRK1 230.0 to EASTWOOD 230.0 Circuit 1 Line PARDEE - Pastora - Warner 230 KV line	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	105.9	Existing Pastoria Energy Facility RAS
	line_P6_201698_Line MAMMOTH 230.0 to BIG CRK3 230.0 Circuit 1 Line PARDEE 230.0 to BAILEY 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	108.4	Existing Pastoria Energy Facility RAS
	line_P6_201703_Line MAMMOTH 230.0 to BIG CRK3 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	108.4	Existing Pastoria Energy Facility RAS
	line_P6_201704_Line MAMMOTH 230.0 to BIG CRK3 230.0 Circuit 1 Line PASTORIA 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	112.8	Existing Pastoria Energy Facility RAS
	line_P6_201713_Line MAMMOTH 230.0 to BIG CRK3 230.0 Circuit 1 Line PARDEE - Pastora - Warner 230 KV line	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	113.2	Existing Pastoria Energy Facility RAS
24087 MAGUNDEN 230 24401 ANTELOPE 230 2 1	line_P6_201984_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to BAILEY 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	103.1	Existing Pastoria Energy Facility RAS
	line_P6_201987_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	101.5	Existing Pastoria Energy Facility RAS
	line_P6_201989_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	109.1	Existing Pastoria Energy Facility RAS
24114 PARDEE 230 24115 PASTORIA 230 1 1	line_P6_202124_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	103.3	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202126_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	103.0	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202136_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE - Pastora - Warner 230 KV line	P6	N-1-1	<100	<100	<100	100.6	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202322_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	101.7	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202324_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	100.5	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
24114 PARDEE 230 24217 WARNETAP 230 1 1	line_P6_201984_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to BAILEY 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	113.4	Existing Pastoria Energy Facility RAS
	line_P6_201985_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	101.4	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_201987_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	116.6	<100	109.2	<100	<100	<100	108.3	Existing Pastoria Energy Facility RAS
	line_P6_201988_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	109.6	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202054_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 2 Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	102.1	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202056_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 2 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	117.2	<100	109.9	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202057_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 2 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	110.4	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202122_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PASTORIA 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	104.9	<100	<100	<100	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202124_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	121.3	<100	<100	<100	<100	<100	106.8	Existing Pastoria Energy Facility RAS
	line_P6_202125_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	119.0	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
24114 PARDEE 230 24403 BAILEY 230 1 1	line_P6_202322_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	119.4	<100	<100	<100	<100	<100	100.9	Existing Pastoria Energy Facility RAS
	line_P6_202323_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	108.9	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_201980_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	109.7	Existing Pastoria Energy Facility RAS
	line_P6_201984_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to BAILEY 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	<100	<100	<100	<100	122.3	Existing Pastoria Energy Facility RAS
	line_P6_201987_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	108.4	<100	105.2	<100	<100	<100	117.2	Existing Pastoria Energy Facility RAS
24115 PASTORIA 230 24217 WARNETAP 230 1 1	line_P6_201988_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	105.6	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202056_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 2 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	109.0	<100	105.9	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202057_Line MAGUNDEN 230.0 to ANTELOPE 230.0 Circuit 2 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	108.3	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202124_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	113.0	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202125_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	110.7	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202322_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	111.2	<100	<100	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
	line_P6_202323_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	<100	<100	<100	<100	<100	104.8	<100	<100	<100	<100	Existing Pastoria Energy Facility RAS
24301 BIG CRK1 230 24235 RECTOR 230 1 1	line_P6_201306_Line BIG CRK2 230.0 to BIG CRK3 230.0 Circuit 1 Line BIG CRK2 230.0 to BIG CRK3 230.0 Circuit 1	P6	N-1-1	<100	104.4	104.1	104.5	<100	<100	104.4	<100	<100	<100	Existing Big Creek/San Joaquin Valley RAS
	line_P6_201309_Line BIG CRK2 230.0 to BIG CRK3 230.0 Circuit 1 Line BIG CRK6 230.0 to BIG CRK3 230.0 Circuit 1	P6	N-1-1	<100	121.3	120.8	121.6	<100	<100	121.3	<100	<100	<100	Existing Big Creek/San Joaquin Valley RAS
	line_P6_201463_Line BIG CRK3 230.0 to RECTOR 230.0 Circuit 1 Line BIG CRK4 230.0 to BIG CRK3 230.0 Circuit 1	P6	N-1-1	<100	101.0	100.2	100.9	<100	<100	101.1	<100	<100	<100	Existing Big Creek/San Joaquin Valley RAS
24302 BIG CRK2 230 24303 BIG CRK3 230 1 1	line_P6_201066_Line BIG CRK1 230.0 to RECTOR 230.0 Circuit 1 Line BIG CRK2 230.0 to BIG CRK6 230.0 Circuit 1	P6	N-1-1	<100	108.4	108.2	108.2	<100	<100	108.4	<100	<100	<100	Congestion management and system re-dispatch after initial contingency
	line_P6_201069_Line BIG CRK1 230.0 to RECTOR 230.0 Circuit 1 Line BIG CRK8 230.0 to BIG CRK3 230.0 Circuit 1	P6	N-1-1	<100	124.5	124.2	124.1	<100	<100	124.6	<100	<100	102.2	Congestion management and system re-dispatch after initial contingency
24302 BIG CRK2 230 24305 BIG CRK6 230 1 1	line_P6_201065_Line BIG CRK1 230.0 to RECTOR 230.0 Circuit 1 Line BIG CRK2 230.0 to BIG CRK4 230.0 Circuit 1	P6	N-1-1	<100	109.0	108.8	108.8	<100	<100	109.0	<100	<100	<100	Existing Big Creek/San Joaquin Valley RAS
24303 BIG CRK3 230 24235 RECTOR 230 1 1	line_P6_200728_Line SPRINGV. 230.0 to BIG CRK4 230.0 Circuit 1 Line BIG CRK1 230.0 to RECTOR 230.0 Circuit 1	P6	N-1-1	<100	120.8	119.9	121.7	109.3	<100	120.9	<100	<100	NotConv	Congestion management and system re-dispatch after the second contingency
	line_P6_201068_Line BIG CRK1 230.0 to RECTOR 230.0 Circuit 1 Line BIG CRK4 230.0 to BIG CRK3 230.0 Circuit 1	P6	N-1-1	<100	108.9	108.0	105.6	<100	<100	107.0	<100	<100	<100	Existing Big Creek/San Joaquin Valley RAS
	line_P6_201073_Line BIG CRK1 230.0 to RECTOR 230.0 Circuit 1 Line RECTOR 230.0 to BIG CRK3 230.0 Circuit 2	P6	N-1-1	112.1	143.5	136.7	138.9	123.9	<100	138.3	105.3	132.7	Existing Big Creek/San Joaquin Valley RAS	
	line_P6_201544_Line BIG CRK4 230.0 to BIG CRK3 230.0 Circuit 1 Line RECTOR 230.0 to BIG CRK3 230.0 Circuit 2	P6	N-1-1	<100	105.0	104.3	104.8	<100	<100	105.1	<100	<100	<100	Existing Big Creek/San Joaquin Valley RAS
24306 BIG CRK8 230 24303 BIG CRK3 230 1 1	line_P6_201065_Line BIG CRK1 230.0 to RECTOR 230.0 Circuit 1 Line BIG CRK2 230.0 to BIG CRK3 230.0 Circuit 1	P6	N-1-1	<100	125.9	125.6	125.6	102.0	<100	126.0	<100	<100	104.9	Existing Big Creek/San Joaquin Valley RAS
24402 ANTELOPE 66.0 24401 ANTELOPE 230 1 1	line_P6_205699_Line ANTELOPE 66.0 to NEENACH 66.0 Circuit 1 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 2	P6	N-1-1	<100	<100	104.8	<100	<100	<100	<100	<100	<100	<100	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205696_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 2	P6	N-1-1	<100	<100	108.3	<100	<100	<100	<100	<100	<100	<100	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205697_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 2	P6	N-1-1	<100	<100	107.9	<100	<100	<100	<100	<100	<100	<100	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205622_Line NEENACH 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 2	P6	N-1-1	<100	<100	104.9	<100	<100	<100	<100	<100	<100	<100	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
	tran_P6_207154_Line ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 2 0.00 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 1	P6	N-1-1	131.3	159.1	199.8	102.2	118.2	<100	164.7	<100	<100	131.3	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
24402 ANTELOPE 66.0 24401 ANTELOPE 230 2 1	line_P6_205701_Line ANTELOPE 66.0 to NEENACH 66.0 Circuit 1 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 4	P6	N-1-1	<100	<100	108.2	<100	<100	<100	<100	<100	<100	<100	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205694_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 1	P6	N-1-1	<100	<100	110.3	<100	<100	<100	<100	<100	<100	<100	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205697_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.0 to ANTELOPE 230.0 Circuit 4	P6	N-1-1	<100	<100	111.8	<100	<100	<100	<100	<100	<100	<100	Congestion management and emerging existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205625_Line NEENACH													

24402 ANTELOPE 66.0 24401 ANTELOPE 230 4 1	line_P6_205699_Line ANTELOPE 66.0 to NEENACH 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2	P6	N-1-1	< 100	< 100	107.8	< 100	< 100	< 100	< 100	< 100	< 100	< 100	congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205694_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 1	P6	N-1-1	< 100	< 100	109.5	< 100	< 100	< 100	< 100	< 100	< 100	< 100	congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205895_Line BAILEY 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2	P6	N-1-1	< 100	< 100	111.4	< 100	< 100	< 100	< 100	< 100	< 100	< 100	congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency
	line_P6_205923_Line NEENACH 66.0 to TAP 85 66.0 Circuit 1 Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 2	P6	N-1-1	< 100	< 100	107.9	< 100	< 100	< 100	< 100	< 100	< 100	< 100	congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency
	tran_P6_207126_Tran ANTELOPE 66.00 to ANTELOPE 230.00 Circuit 1 0.00 Tran ANTELOPE 66.00 to ANTELOPE	P6	N-1-1	131.6	150.4	200.2	102.4	118.5	< 100	165.0	< 100	131.6	< 100	congestion management and energizing existing spare transformer after initial contingency and shed load after the second contingency
24402 ANTELOPE 66.0 24420 NEENACH 66.0 1 1	line_P6_202257_Line PARDEE 230.0 to BAILEY 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	< 100	113.0	133.8	< 100	132.9	< 100	114.5	< 100	135.9	< 100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency
	tran_P6_207228_Tran BAILEY 66.00 to BAILEY 230.00 Circuit 2 0.00 Tran BAILEY 66.00 to BAILEY	P6	N-1-1	< 100	114.3	132.5	< 100	134.1	< 100	114.9	< 100	133.1	< 100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency
24403 BAILEY 230 24115 PASTORIA 230 1 1	line_P6_201989_Line MAGINDEN 230.0 to ANTELOPE 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	< 100	< 100	< 100	< 100	< 100	< 100	< 100	< 100	< 100	< 100	Existing Pastoria Energy Facility RAS
	line_P6_202125_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	< 100	< 100	< 100	108.2	< 100	< 100	< 100	< 100	< 100	< 100	Existing Pastoria Energy Facility RAS
	line_P6_202126_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	< 100	< 100	< 100	109.8	< 100	< 100	< 100	< 100	< 100	< 100	System re-dispatch after initial contingency
	line_P6_202138_Line ANTELOPE 230.0 to PARDEE 230.0 Circuit 1 Line Pardee - Pastoria - Warner 230 kV line	P6	N-1-1	< 100	< 100	< 100	107.4	< 100	< 100	< 100	< 100	< 100	< 100	Existing Pastoria Energy Facility RAS
	line_P6_202323_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line PARDEE 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	< 100	< 100	< 100	107.7	< 100	< 100	< 100	< 100	< 100	< 100	Existing Pastoria Energy Facility RAS
line_P6_202324_Line PASTORIA 230.0 to EDMONSTN 230.0 Circuit 1 Line PARDEE 230.0 to WARNETAP 230.0 Circuit 1	P6	N-1-1	< 100	< 100	< 100	109.3	< 100	< 100	< 100	< 100	< 100	< 100	Existing Pastoria Energy Facility RAS	
24404 BAILEY 66.0 24452 TAP 85 66.0 1 1	line_P6_202257_Line PARDEE 230.0 to BAILEY 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	123.1	119.8	120.2	119.4	< 100	< 100	120.8	125.7	< 100	< 100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency
	tran_P6_207228_Tran BAILEY 66.00 to BAILEY 230.00 Circuit 2 0.00 Tran BAILEY 66.00 to BAILEY	P6	N-1-1	120.6	118.8	125.2	119.5	< 100	< 100	121.0	123.3	< 100	< 100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency
24420 NEENACH 66.0 24452 TAP 85 66.0 1 1	line_P6_202257_Line PARDEE 230.0 to BAILEY 230.0 Circuit 1 Line BAILEY 230.0 to PASTORIA 230.0 Circuit 1	P6	N-1-1	143.4	138.8	138.8	139.6	115.3	< 100	140.3	131.6	118.0	< 100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency
	tran_P6_207228_Tran BAILEY 66.00 to BAILEY 230.00 Circuit 2 0.00 Tran BAILEY 66.00 to BAILEY	P6	N-1-1	143.5	139.2	142.1	139.7	116.3	< 100	142.0	131.8	115.4	< 100	Split Antelope-Bailey 66 kV System per existing SCE operating procedure after initial contingency

















2024-2025 ISO Reliability Assessment - Preliminary Study Results

Study Area: **SCE Tehachapi & Big Creek Corridor**



Single Contingency Load Drop

Worst Contingency	Category	Category Description	Amount of Load Drop (MW)								Potential Mitigation Solutions	
			2026 Summer Peak	2029 Summer Peak	2034 Summer Peak	2029 Summer-Off Peak	2026 Spring-Off Peak	2029 Spring-Off Peak	2029 SP High CEC Forecast	2026 SP Heavy Renewable & Min Gas Gen		2026 Spring Shoulder-Peak

No single contingency resulted in total load drop of more than 250 MW

2024-2025 ISO Reliability Assessment - Preliminary Study Results

Study Area: **SCE Tehachapi & Big Creek Corridor**



Single Source Substation with more than 100 MW Load

Substation	Load Served (MW)									Potential Mitigation Solutions
	2026 Summer Peak	2029 Summer Peak	2034 Summer Peak	2029 Summer-Off Peak	2026 Spring-Off Peak	2029 Spring-Off Peak	2029 SP High CEC Forecast	2026 SP Heavy Renewable & Min Gas Gen	2026 Spring Shoulder-Peak	

No single source substation with more than 100 MW